

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School /2025/SZ/1155

Dated: 18/09/2025

FIRE SAFETY CERTIFICATE

Certified that the **Vasant Valley School** at **Sector-C, Vasant Kunj, New Delhi-110070** comprised of ground plus two upper floors (02 Blocks), owned/occupied by Vasant Valley School was issued FSC by this department vide letter No. F.6/MS/DFS/School/2022/SZ/1097 dated 30-09-2022. The premise was re-inspected by officer concern of this department on 07/08/2025 in presence of Mr. A. P John (Head of Admin) and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Educational**" Group-B with effect from 18/09/2025 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...18/09/2025 at New Delhi by

Wuf
9/9/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Authorized Signatory, Vasant Valley School, Sector-C, Vasant Kunj, New Delhi-110070
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."